

CITY OF KELOWNA

BYLAW NO. 8966

Amendment No. 8 to City of Kelowna Electricity Regulation Bylaw No. 7639

The Municipal Council of the City of Kelowna, in open meeting assembled, enacts as follows:

1. THAT City of Kelowna Electricity Regulation Bylaw No. 7639 be amended by:
 - (a) Amending **Schedule B – Electrical Services Regulations** as follows:
 - (i) Replacing **Section 1 – General** with the following:

“Section 1 – General
B-1. APPLICATION FOR SERVICE

Electrical **service** shall be supplied under the provisions of the *Local Government Act*.

B-2. SERVICE LOCATION

The Electrical Contractor shall check with the **City** regarding building **service** and electrical meter location(s).

B-3. MINIMUM SERVICE CAPACITY OF RESIDENTIAL

All temporary and new permanent single phase residential **services** shall be 240 volts, 3 wire and in all new dwelling units the **service** shall meet the minimum requirements of the *Electrical Safety Act*. When major alterations are made to a single dwelling unit and/or to the electrical wiring, any deficiencies in the **service** should be upgraded to ensure adequate **service** capacity. Only one **service** shall be allowed. The **service** must be installed underground in a minimum size conduit of 7.62 mm (3 inches) if premise is located in an urban or village centre as outlined in the Kelowna Official Community Plan (1994-2013) Bylaw No. 7600 the City of Kelowna Subdivision, Development and Servicing Bylaw No. 7900.

B-4. MULTI-FAMILY DWELLINGS AND APARTMENT BUILDINGS

Service requirements shall conform with the requirements covered in Section V of this schedule. All buildings containing more than two dwelling units must have a separate electrical room.

B-5. COMMERCIAL SERVICES

The **City** requires that all commercial **services** be underground in a conduit no less that 7.62 mm (3 inches) in diameter if premise is located in an urban or village centre as outlined in the Kelowna Official Community Plan (1994-2013) Bylaw No. 7600 the City of Kelowna Subdivision, Development and Servicing Bylaw No. 7900.. All commercial buildings shall have a separate electrical room. Where building design permits, outside access would be preferred.

B-6. INDUSTRIAL SERVICES

The **City** requires that all industrial **services** be underground in a conduit not less than 7.62 mm (3 inches) in diameter if premise is located in an urban or village centre as outlined in the Kelowna Official Community Plan (1994-2013) Bylaw No. 7600 the City of Kelowna Subdivision, Development and Servicing Bylaw No. 7900. All industrial buildings must have a separate electrical room. Where building design permits, outside access would be preferred.”

2. This bylaw will come into full force and be binding on all persons as of the date of adoption.
3. This bylaw may be cited for all purposes as “Bylaw No. 8966 being Amendment No. 8 to City of Kelowna Electricity Regulation Bylaw No. 7639”.

Read a first, second and third time by the Municipal Council this

Adopted by the Municipal Council of the City of Kelowna this

Mayor

City Clerk