

CITY OF KELOWNA

BYLAW NO. 10375

Amendment No. 14 to Fire Prevention Regulations Bylaw No. 6110-88

The Municipal Council of the City of Kelowna, in open meeting assembled, enacts as follows:

1. That "Fire Prevention Regulations Bylaw No. 6110-88" be amended by deleting sub-section 6.6, sub-paragraph (d) (iii) of **PART VI - REGULATIONS** in its entirety and replacing it with a new sub-paragraph (d) (iii) as follows:
 - “(iii) Four (4) lengths of 2 1/2 inch x 50 feet Ultra-Lite Supreme High Rise fire fighting hose with BCT, meeting the requirements of NFPA 1961 latest edition and ULC. Orange in Color;

Twelve (12) 2 1/2” High Rise Hose Straps: Dimensions – 2” wide webbing, 24” long, 2” welded steel loop, 4” red indicator pull tab;

One (1) J140F TFT 65 X 38 shutoff w/1 3/8” waterway 2.5” threads BAT/BCT;

One (1) FSS10 –IF TFT smooth bore tip w/1 1/8” (28mm) TIP/ 1.5” NPSH threads;

Two (2) 65mm female swivel BAT X 60 degree elbow with male BAT 65mm discharge, firelite anodized aluminium;

One (1) 2.5”M/BAT X 1.5”F/NPSH firelite adapter;

One (1) 2 1/2” Inline Pressure Gauge BAT/BCT threads – Akron Style 35;

Two (2) hose spanners; and

One (1) High Rise Appliance Bag (to carry adapters and appliances).”
2. This bylaw shall come into force and take effect as and from the date of adoption.
3. This bylaw may be cited as "Bylaw No. 10375 being Amendment No. 14 to Fire Prevention Regulations Bylaw No. 6110-88".

Read a first and second and third time by the Municipal Council this 12th day of July, 2010.

Adopted by the Municipal Council of the City of Kelowna this

Mayor

City Clerk