CITY OF KELOWNA

BYLAW NO. 10463

Amendment No. 15 to Fire Prevention Regulations Bylaw No. 6110-88

The Municipal Council of the City of Kelowna, in open meeting assembled, enacts as follows:

- 1. That "Fire Prevention Regulations Bylaw No. 6110-88" be amended by adding a new sub-section to PART V1 REGULATIONS, 6.1 GENERAL in it's appropriate location as follows:
 - "(o) Exception:

The following outdoor appliances; outdoor fire pit, outdoor fireplace and barbeque are permitted provided:

- (i) The appliance is CSA/ULC approved;
- (ii) The appliance is fuelled by natural gas, propane or briquette only;
- (iii) Clearance to combustibles a minimum of 1 meter clearance must be maintained from the nearest structure, property line, overhead tree or other combustible material;
- (iv) The installation of gas fuelled outdoor appliances must be approved by the Provincial Gas Inspection Branch and installed in accordance to the manufacturers specifications;
- (v) Supervision -the operator must keep the unit under constant supervision when in use;
- (vi) Provisions for fire protection provide an adequate extinguishing agent such as a fire extinguisher or garden hose; and
- (vii) No person shall burn, or allow to be burned, refuse, waste or wood in a barbeque, outdoor fire pit or outdoor fireplace.
- 2. This bylaw shall come into force and take effect as and from the date of adoption.
- 3. This bylaw may be cited as "Bylaw No. 10463 being Amendment No. 10463 to Fire Prevention Regulations Bylaw No. 6110-88".

Read a first and second and third time by the Municipal Council this

Adopted by the Municipal Council of the City of Kelowna this

-	Mayor
	City Clerk