

CITY OF KELOWNA

BYLAW NO. 10463

Amendment No. 15 to Fire Prevention Regulations Bylaw No. 6110-88

The Municipal Council of the City of Kelowna, in open meeting assembled, enacts as follows:

1. That "Fire Prevention Regulations Bylaw No. 6110-88" be amended by adding a new sub-section to **PART V1 - REGULATIONS, 6.1 GENERAL** in it's appropriate location as follows:

"(o) Exception:

The following outdoor appliances; outdoor fire pit, outdoor fireplace and barbeque are permitted provided:

- (i) The appliance is CSA/ULC approved;
 - (ii) The appliance is fuelled by natural gas, propane or briquette only;
 - (iii) Clearance to combustibles - a minimum of 1 meter clearance must be maintained from the nearest structure, property line, overhead tree or other combustible material;
 - (iv) The installation of gas fuelled outdoor appliances must be approved by the Provincial Gas Inspection Branch and installed in accordance to the manufacturers specifications;
 - (v) Supervision -the operator must keep the unit under constant supervision when in use;
 - (vi) Provisions for fire protection - provide an adequate extinguishing agent such as a fire extinguisher or garden hose; and
 - (vii) No person shall burn, or allow to be burned, refuse, waste or wood in a barbeque, outdoor fire pit or outdoor fireplace.
2. This bylaw shall come into force and take effect as and from the date of adoption.
 3. This bylaw may be cited as "Bylaw No. 10463 being Amendment No. 10463 to Fire Prevention Regulations Bylaw No. 6110-88".

Read a first and second and third time by the Municipal Council this 28th day of February, 2011.

Adopted by the Municipal Council of the City of Kelowna this

Mayor

City Clerk